



6: District Facilities Assessment

Site Data Evaluation for Jones Elementary School

SITE DATA	JONES ES	159
Site Net Acreage:	9.3	
Total Permanent Building Sq. Footage:	28,684	
Total Quantity of Classrooms:	24	
Quantity of Permanent Classrooms	15	
Number of Permanent Buildings	5	
School Program Capacity	406	
Current Enrollment - 2007-08	320	
Projected Enrollment - 2016-17:	290	
Student to Acre Ratio:	34	
Quantity of Portable Classrooms	9	
% of Total Classrooms in Portables	38%	
Quantity of Portable Buildings on Site	9	
Quantity of Undersized Classrooms	1	
% of Undersized Classrooms	4%	
API Rating (2007 Base Statewide Rank)	8	
Quantity of buildings over 50 years	4	
Age of Building-% over 50 years	80%	
FCA Rating	Fair	
Climate Control	II	
ADA Report	Fair	
Delta from Capacity	86	

Site Findings:

- The school is deficient 1,579 sq. ft. of administration & instructional support space to meet district standards
- 9 portables are not certified; 3 portables are over 40 years old

Input from Site Survey:

- Hot water requested in Special Ed rooms
- Natural turf on playing fields requested
- Air-conditioning and ceiling mounted-fans for the Administration bldg reported as needed
- Hot water needed in the Nurse's office bathroom
- Auditorium handicap lift is in need of repair
- Landscaping requested
- Outdoor lights needed in center quad to be able to have evening events for parents and community
- Electrical capacity reported inadequate in teachers lounge and needs to be upgraded

Input from Cluster Meetings:

- Request wireless computer system
- Heating system reportedly does not always work
- PA system requested
- Turf and wireless marquee requested