



## 6: District Facilities Assessment

### Site Data Evaluation for Curie Elementary School

SITE DATA	CURIE ES	77
Site Net Acreage:	10.4	
Total Permanent Building Sq. Footage:	28,852	
Total Quantity of Classrooms:	30	
Quantity of Permanent Classrooms	14	
Number of Permanent Buildings	5	
School Program Capacity	587	
Current Enrollment - 2007-08	594	
Projected Enrollment - 2016-17:	531	
Student to Acre Ratio:	57	
Quantity of Portable Classrooms	16	
% of Total Classrooms in Portables	53%	
Quantity of Portable Buildings on Site	16	
Quantity of Undersized Classrooms	0	
% of Undersized Classrooms	0%	
API Rating (2007 Base Statewide Rank)	10	
Quantity of buildings over 50 years	0	
Age of Building-% over 50 years	0%	
FCA Rating	Poor	
Climate Control	II	
ADA Report	Poor	
Delta from Capacity	-7	

#### Site Findings:

- The school is deficient 2,089 sq. ft. of administration & instructional support space to meet district standards
- 12 Portables on site are not certified, 7 of which are over 40 years old
- 1 classroom is used for art, 1 for science prep, and 1 for support
- Site has requested additional space

#### Input From Site Surveys:

- Addition of science lab requested
- Poor ventilation reported in auditorium and faculty women's restrooms
- Student drop-off area improvements including signage
- MM built wooden wall outside library is reportedly deteriorating and a safety hazard; maintenance/sealing and/or removal of a section requested
- Requested additional storage space

#### Input from Cluster Meetings:

- Mildew problem reported in B2
- Reported that women's low flow toilets do not work properly
- Request that lunch courts be expanded for dual use
- Request natural/artificial turf
- Request new bell system