



6: District Facilities Assessment

Site Data Evaluation for Dailard Elementary School

SITE DATA	DAILARD ES	78
Site Net Acreage:	10.1	
Total Permanent Building Sq. Footage:	53,001	
Total Quantity of Classrooms:	26	
Quantity of Permanent Classrooms	26	
Number of Permanent Buildings	6	
School Program Capacity	552	
Current Enrollment - 2007-08	525	
Projected Enrollment - 2016-17:	427	
Student to Acre Ratio:	52	
Quantity of Portable Classrooms	0	
% of Total Classrooms in Portables	0%	
Quantity of Portable Buildings on Site	0	
Quantity of Undersized Classrooms	8	
% of Undersized Classrooms	31%	
API Rating (2007 Base Statewide Rank)	10	
Quantity of buildings over 50 years	0	
Age of Building-% over 50 years	0%	
FCA Rating	Good	
Climate Control	III w/ 100% AC	
ADA Report	Fair	
Delta from Capacity	27	

Site Findings:

- The school is deficient 234 sq. ft. of administration & instructional support space to meet district standards
- There are no Portables currently on site

Input From Site Surveys:

- Lower playground PE facilities and equipment requested
- Requested safety lighting
- Request windows and noise reduction measures in loft classrooms
- A/C repair or upgrade requested
- One of two fire panels reported as requiring constant maintenance

Input from Cluster Meetings:

- Request intercom/paging system and wireless network
- Request replacement of loft classrooms, with increased classroom size and space for specialty classrooms
- Request restructuring of administration building for security monitoring
- Parking lot needs separate entrance/exit for safety