



6: District Facilities Assessment

Site Data Evaluation for Johnson Elementary School

SITE DATA	JOHNSON ES	157
Site Net Acreage:	8.2	
Total Permanent Building Sq. Footage:	26,760	
Total Quantity of Classrooms:	30	
Quantity of Permanent Classrooms	14	
Number of Permanent Buildings	5	
School Program Capacity	525	
Current Enrollment - 2007-08	357	
Projected Enrollment - 2016-17:	334	
Student to Acre Ratio:	44	
Quantity of Portable Classrooms	16	
% of Total Classrooms in Portables	53%	
Quantity of Portable Buildings on Site	17	
Quantity of Undersized Classrooms	0	
% of Undersized Classrooms	0%	
API Rating (2007 Base Statewide Rank)	6	
Quantity of buildings over 50 years	0	
Age of Building-% over 50 years	0%	
FCA Rating	Poor	
Climate Control	III	
ADA Report	Poor	
Delta from Capacity	168	

Site Findings:

- The school is deficient 1,463 sq. ft. of administration & instructional support space to meet district standards
- There are no portables over 40 years old

Input from Site Survey:

- Technology needed to support STEM (Science, Technology, Engineering and Math) magnet program
- Poor ventilation and no HVAC reported in library and professional development room/administration buildings
- Additional exterior lighting and updated perimeter fencing needed due to security concerns
- Additional kitchen space needed to accommodate kitchen equipment to serve student population
- Turf field reported as needed
- Building and Campus replacement reported as a high priority due to dilapidating infrastructure and age of buildings

Input from Cluster Meetings:

- Additional data drops needed, due to increased enrollment
- Kindergarten classrooms need restrooms
- Request more instructional support spaces
- Request science classrooms/labs
- Request additional parking and bus turnaround
- Cracks in asphalt reported
- Request renovation of restrooms and office