

**SECTION 26 00 00: GENERAL ELECTRICAL SPECIFICATION****PART 1 - GENERAL****1.01 RELATED DOCUMENTS**

- A. The RFP and all Attachments.
- B. Section 26 60 00: Photovoltaic System Specifications
- C. Section 05 90 00: PV Mounting Specifications
- D. SDUSD Guide Specifications for Division 26

*NOTE: Where this specification and SDUSD Standard Specifications are in conflict, the more stringent shall apply. Contractor shall identify conflicts and confirm recommended equipment or procedures with the District.*

**1.02 GENERAL**

- A. This specification defines the general electrical requirements for complete and fully functioning photovoltaic systems at each site. The design and installation shall conform to all requirements as defined by the applicable codes, laws, rules, regulations and standards as specified in the RFP.
- B. The Contractor shall include all items and all work reasonable inferred by these specifications and the RFP. If the Contractor is in doubt as to the intent of any portion of these specifications and the RFP, or necessary information is omitted, the Contractor shall notify the Owner in writing for clarifications or corrections to be provided by addendum.
- C. All design documents, cut sheets, and technical specifications shall be submitted, reviewed and accepted by the Owner per the guidelines specified in RFP Attachment A3-Submittals and Project Acceptance.

**1.03 WORK INCLUDED**

- A. The work shall include the design of the electrical system, materials, equipment, fabrication, installation and tests in conformity with applicable codes and professionally recognized standards.
- B. The electrical design shall be fully developed, including but not limited to the following:
  - 1. Description and supportive calculations for all power and grounding systems.
  - 2. Location and layout of all system equipment.
  - 3. Site plans, elevations, schedules, equipment arrangement and detailed drawings
  - 4. All items of a given type shall be the products of the same manufacturer.
  - 5. Single line diagrams including local utility system tie-ins.
  - 6. Evaluation of existing switchgear and Utility transformers for interconnection compatibility.
  - 7. All other drawings, calculations, details, and schedules required for the system design.
- C. All required construction documents and compliance documentation.
- D. Temporary power and lighting as required for construction.

- E. All required incidental work, such as excavating, directional boring, backfilling, roof flashing, fire stopping, waterproofing, pavement repair, striping, and testing.
- F. Any other electrical work as might reasonably be implied as required, even though not specifically mentioned herein or shown on the drawings
- G. Design and construction coordination with all other disciplines and trades.
- H. All other utilities, labor, materials, apparatus, tools, equipment, transportation, and special or occasional services as required.

**1.09 CONDITIONS AT SITE:**

- A. Contractor is responsible for familiarizing themselves with all discernible site conditions. No extra payment will be allowed for work required because of these conditions, whether specifically mentioned or not.
- B. Lines of other services that are damaged as a result of this work shall promptly be repaired at no expense to the Owner and to the complete satisfaction of the Owner.

**1.10 QUALITY ASSURANCE**

- A. General:
  - 1. Construction Documents shall be designed and signed by a validated, registered professional engineer in the State of California.
- B. Conformance:
  - 1. All equipment and accessories shall be the product of a manufacturer regularly engaged in its manufacture.
  - 2. Supply all new equipment and accessories free from defects and listed by Underwriter's Laboratories, Inc., or bearing its label or label of a Nationally Recognized Testing Laboratory (NRTL).
  - 3. All items of a given type shall be the products of the same manufacturer.
  - 4. If after contract is awarded, minor changes and additions are required by aforementioned authorities, they shall be included at Contractor's expense.
- C. Coordination:
  - 1. Contractor shall become familiar with the conditions at each job site and plan the installation of the electrical work to conform with the existing conditions so as to provide the best possible assembly of the combined work of all trades.
- D. Coordination Drawings for electrical installation:
  - 1. Prepare Coordination Drawings, to scale. Detail major elements, components and systems of electrical equipment and materials in relation to each other and to other systems, installations, and building components. Indicate locations and space requirements for installation, access and working clearances. Show where sequence and coordination of installations are important to the efficient flow of the Work. Indicate the following:
    - a. Provisions for scheduling, sequencing, moving and positioning large equipment in or on the site or buildings during construction.
    - b. Plans, elevations and details including the following:
      - 1) Clearances to meet safety requirements and for servicing and maintaining

equipment, including space for equipment disassembly required for periodic maintenance.

- 2) Equipment support details.
- 3) Exterior wall, roof and foundation penetrations of cable and raceway; and their relation to other penetrations and installations.
- 4) Fire-rated wall and roof penetrations by electrical installations.
- 5) Sizes and locations of required concrete pads and bases.
- 6) Grounding system details.

#### 1.12 DELIVERY, STORAGE AND HANDLING

- A. Protection: Use all means necessary to protect the materials of this Section before, during, and after installation and to protect the work and materials of all trades.
- B. Delivery and Storage: Deliver all materials to the job site in their original containers with all labels intact and legible at time of use. Store in strict accordance with approved manufacturers' recommendations. All deliveries are to be made to the Contractor's job trailer or approved storage location. Under no circumstances shall owner be responsible for accepting deliveries.
- C. Replacements: In the event of damage, immediately make all repairs and replacements necessary to the approval of the Owner and at no additional cost to the Owner.
- D. Contractor shall personally, or through an authorized representative, check all materials upon receipt at jobsite for conformance with approved shop drawings and/or plans and specifications.

#### 1.13 SCHEDULING/SEQUENCING

- A. Contractor shall coordinate all schedules and sequencing of electrical work with Owner.
- B. Place orders for all equipment in time to prevent any delay in construction schedule or completion of project. If any materials or equipment are not ordered in time, additional charges made by equipment manufacturers to complete their equipment in time to meet the construction schedule, together with any special handling charges, shall be borne by the Contractor.
  1. Contractor shall coordinate production and delivery schedule for all Owner-supplied equipment with the equipment suppliers to ensure that all Owner-supplied equipment is delivered to site in coordination with the construction schedule and in such a manner as to cause no delays in completion of the Contract as scheduled.

#### 1.14 WIND LOADING AND SEISMIC DESIGN

- A. Comply with all applicable codes and standards and provide wind load restraints for all equipment installed under this contract that requires restraint. The photovoltaic array wind loading restraint shall be designed as required by the AHJs. The photovoltaic array shall be designed to accommodate lateral displacement in the event of an earthquake based on a nonlinear response-history seismic analysis for the appropriate seismic criteria.

#### 1.15 PERMITS AND INSPECTIONS

- A. Contractor shall obtain all required permits and arrange for all required inspections, including

all utility company requirements (including, but not limited to, the complete interconnect process and securing permission to operate (PTO)), inspections, and sign-offs.

- B. Do not allow or cause any of the work to be covered or enclosed until it has been tested and/or inspected.

**PART 2 - PRODUCTS****2.01 MATERIALS**

- A. Materials of the same type or classification, used for the same purpose, shall be the product of the same manufacturer.

**2.02 POSTED OPERATING INSTRUCTIONS**

- A. Furnish approved operating instructions for systems and equipment where indicated in the technical sections for use by operation and maintenance personnel. The operating instructions shall include wiring diagrams, control diagrams, and control sequence for each principal system and equipment. Print or engrave operating instructions and frame under glass or in approved laminated plastic. Post instructions as directed. Attach or post operating instructions adjacent to each principal system and equipment including startup, proper adjustment, operating, lubrication, shutdown, safety precautions, procedure in the event of equipment failure, and other items of instruction as recommended by the manufacturer of each system or equipment. Provide weather-resistant materials or weatherproof enclosures for operating instruction exposed to the weather. Operating instruction shall not fade when exposed to sunlight and shall be secured to prevent easy removal or peeling.

**2.03 CATALOGED PRODUCTS / SERVICE AVAILABILITY**

- A. Materials and equipment shall be current products by manufacturers regularly engaged in the production of such products. Specified product models shall have been in satisfactory commercial or industrial use for a minimum of 2 years prior to design. The 2-year period shall include applications of equipment and materials under similar circumstances and of similar size. The 2-year period shall be satisfactorily completed by a product for sale on the commercial market through advertisements, manufacturers' catalogs, or brochures. Products having less than a 2-year field service record will be acceptable if a certified record of satisfactory field operation for not less than 6,000 hours, exclusive of the manufacturers' factory or laboratory tests, is furnished. The equipment items shall be supported by service organizations which are reasonable convenient to the equipment installation in order to render satisfactory service to the equipment on a regular and emergency basis during the warranty period of the contract.

**2.04 ACCEPTABLE MANUFACTURERS**

- A. Materials shall be of make mentioned elsewhere in this specification. All materials shall be the best of their several kinds, perfectly new and approved by the Underwriters' Laboratories or an NRTL.

**2.05 BASIC ELECTRICAL EQUIPMENT AND MATERIALS**

- A. Inverters and PV Modules – See Specification 266000.
- B. AC Panelboards:

1. As manufactured by Cutler-Hammer, Square D, General Electric, Siemens, IEM, or to match existing equipment at each Site, wherever possible. Equipment shall be NEMA 3R outdoors, NEMA 1 surface mounted in unfinished interior locations and flush mounted in finished and occupied spaces. Provide housekeeping pads for all floor or slab mounted equipment.
  2. Enclosures: code gauge galvanized sheet steel with welded full flange end pieces, stretcher- leveled steel trim, back pan and door or painted steel or powder coated steel. All surface mounted panels to have enclosures painted in gray enamel. All flush mounted panels to have cover painted to match adjacent surface.
  3. Phase and ground bussing of copper with silver-plated or tin-plated or nickel plated contact surfaces.
  4. Trims on surface-mounted cabinets secured with nickel-plated screws with cup washers, bottom of all trims to have lugs for resting on cabinet flange.
  5. Panels shall be 20 inches minimum in width, provided with approved gutter space, barriers and adjustable supports. Doors mounted with concealed hinges provided with combination spring latch and lock. Doors and trims and surface mounted cabinets primed and finished with one coat baked on gray enamel.
  6. Each panel shall be equipped with a copper ground bus.
  7. All panels shall be fully bussed to accept future circuit breakers.
- C. Distribution Low Voltage Dry-Type Transformers (120/208V and 277/480V):
1. Ventilated type, NEMA 3R where used outdoors.
  2. Transformer shall be 3 phase, 60 Hertz. Primary winding shall be Delta connected and secondary winding shall be Wye connected. The temperature rise at rated voltage and full load shall not exceed 150 degrees C with a 220 degrees C U.L. Component Recognized Insulation System. The windings shall be Aluminum or Copper.
  3. The higher voltage winding shall have quantity (6) 2.5% taps - (2) FCAN and (4) FCBN. Set secondary voltage for 120/208V.
  4. Transformer terminals shall be front connected for ease of installation and maintenance.
  5. Where the transformers are installed outdoors provide weatherproof drip cover, rodent screen and a NEMA 3R rating of the enclosure.
  6. Transformers shall be suitable to carry the PV load characteristics and in the direction of power flow required for the PV system power production.
- D. Circuit Breakers:
1. Circuit breakers shall be molded case rated 250 or 480 volt, multiple or single pole with amperage ratings as required for each circuit. All breakers to be bolt on, manually operated with "de-ion" arc chutes. Plug-in breakers are not acceptable.
  2. Circuit breakers shall be rated to interrupt the available short circuit current at the point of application.
- E. Raceways and Conduit Bodies: Only the raceways specified below shall be utilized on these projects. Substitutions shall be pre-approved in writing:
1. Rigid Type - hot dip galvanized or sherardized steel, to be used at all exterior locations, below grade, or in concrete slab, and to 18" on either side of structural expansion joints in floor slabs, with completely watertight, threaded fittings throughout.
    - a. All rigid steel conduit couplings and elbows in soil or concrete or under membrane to be ½ lap wrapped with Scotch #50 tape and threaded ends coated with T&B #S.C.40

- rust inhibitor prior to installation of couplings.
- b. ½ lap wrap all rigid steel conduit stub-ups from slab or grade to 6" above finished grade level with Scotch #50 tape.
  - c. In lieu of rigid steel conduit for power and control raceways and branch circuit conduits in soil or concrete slabs, "Schedule 40" PVC with Schedule 80 PVC conduit elbows and stub-ups may be used with code size (minimum No. 12) ground wire. A "stub-up" is considered to terminate 6" above the finished surface.
    - 1) Schedule 80 PVC conduit shall be used in all concrete footings or foundations and to 18" of either side of footings or foundation walls.
    - 2) Schedule 80 PVC conduit shall be used in all concrete masonry unit (CMU) walls or columns.
2. Owner preference for horizontal directional boring where feasible. Conduit installed using horizontal directional boring (HDB) shall include tracer tape or traceable conduit. Minimum depth of the conduit shall be per NEC 2011 Article 300.5. The Contractor is responsible for demonstrating that all conduits installed utilizing horizontal boring meets the minimum depth requirement and is solely responsible for any remediation costs and schedule impacts if the specification is not met. Contractor shall provide documentation of final depth and routes of all conduit installed in horizontal bores.
  3. Conduit buried underground shall be suitable for the application and compliant with all applicable codes. PVC shall be constructed of a virgin homopolymer PVC compound and be manufactured according to NEMA and UL specifications. All PVC conduit feeders shall contain an appropriate copper grounding conductor sized per NEC requirements and continuity shall be maintained throughout conduit runs and pull boxes. Minimum conduit size shall be ¾". A metallic tracing/caution tape shall be installed in the trench over all buried conduit.
  4. All conduit runs in concrete floor slabs (where allowed) shall be installed to comply with all applicable UBC and structural codes to maintain the structural integrity of the floor slab. Where conflicts occur, alternate routing shall be provided at no additional cost to the Owner.
  5. Electrical Metallic Tubing (EMT) shall be used exposed in electrical and mechanical rooms and in unfinished spaces and in concealed and furred spaces, made up with steel watertight or steel set screw type fittings and couplings. Set screws shall have hardened points. Cast fittings are unacceptable. EMT may be used in exterior installations where allowed by NEC, DSA, City code and any other applicable code. All exterior fittings shall be watertight. EMT may not be installed in areas subject to severe physical damage, including in any carport location with potential for vehicle strike.
  6. All exposed conduits on sides of buildings, or in other visible areas, shall be painted to match adjacent finishes, after complete installation.
  7. Fasten conduits securely to boxes with locknuts and bushings to provide good electrical continuity.
  8. To facilitate pulling of conductors, install junction boxes as required.
  9. If any empty conduits are provided as part of the projects, they shall be provided with a pull-wire.
  10. If conduits are to pass through structural expansion joints in floor slab, rigid galvanized conduit shall be used 18" on either side of joint, complete with Appleton expansion couplings and bonding jumpers, or equal. All above grade expansion joint crossings shall also utilize expansion joint couplings or flex conduit transitions as required for each

- particular installation. No solid conduits shall be allowed to cross expansion joints without proper provisions for building and seismic movement.
11. Provide thermal expansion fittings or provisions, per NEC 300.7(b), for all raceways subject to high temperatures in direct exposure to sunlight. Provide expansion provisions where more than 0.25" of expansion is calculated.10. Minimum cover of conduits in ground outside of building - 36 inches, unless otherwise noted.
  12. Provide and install exterior wall conduit seals and cable seals in the locations listed below. Coordinate installation and scheduling with other trades:
    - a. Conduit seals through exterior wall or slab (below grade): O.Z. Gedney series "FSK" in new cast in concrete locations, series "CSM" in cored locations.
    - b. Conduit seals through exterior wall or slab (above grade): O.Z. Gedney series "CSMI."
    - c. Cable seals at first interior conduit termination after entry through exterior wall or slab: O.Z. Gedney series "CSBI." Coordinate quantity of conductors at each location.
- F. Junction Boxes / Pull Boxes:
1. One piece steel knockout type drawn j-boxes, unless otherwise noted, sized as required for conditions at each location.
  2. J-boxes for wet locations, cast aluminum FS or FD type with cast aluminum gasketed spring lid cover. Weatherproof "Bell" type boxes are not acceptable.
  3. Pull boxes to be NEMA 1 (indoor) or NEMA 3R (outdoor), sized per code, with grey enamel finish, steel construction, and screw-on covers.
  4. All connectors from conduit to junction or outlet boxes shall have insulated throats. Connectors shall be manufactured with insulated throats as integral part. Insertable insulated throats are unacceptable.
  5. Conduit Bodies: Malleable iron type, with lubricated spring steel clips over edge of conduit body, O-Z/Gedney type EW, or equal.
- G. Site Pull boxes: All site pull boxes shall be flush in-ground concrete, with engraved covers identifying service use (i.e. electrical, communications, etc.). Boxes shall be NEMA 250, Type 6, outside flanged, with recessed cover for flush mounting, by Christy or equal, with required depth to provide box and conduit depths shown or required.
1. Provide concrete covers for all boxes in planted or paved areas (up to available concrete cover size).
  2. Provide galvanized steel covers for all larger boxes (when concrete is not available), or in traffic areas. No cast iron covers.
  3. Provide bolted covers and slab bottoms (with grouted perimeter) or vault type boxes for all electrical distribution and signal system pull boxes used for site distribution, to prevent rodent entry. No collar type boxes with dirt or gravel bottoms.
  4. Provide drain hole at bottom of all vault type boxes, with loose aggregate base below, for proper drainage.
  5. All covers to be completely flush with finished adjacent surfaces.
  6. Provide galvanized steel H2O rated covers and installation of box rated for H2O in all traffic areas.
- I. Wire and Cable:
1. 600 or 1,000-volt class (as required for system design), insulation color coded, minimum No. 12 AWG for DC string circuits or AC circuits.

2. All conductors shall be copper.
3. Insulation type:
  - a. Standard locations: Conductors shall be Type PV or THWN or THWN-2 or RHH, RHW-2, USE-2 for wet and dry locations. All AC wire sizes used shall be based on a 75 degree insulation rating, unless specifically used with 90 degree rated devices. For wires/cables with 90 deg C insulation, the 90 deg C ampacity ratings shall be used for cable sizing before conditions of use de-rates are applied per NEC. All DC wire sizes shall be based on 90 degree insulation rating, when used with 90 degree rated PV equipment and components.
  - b. All conductors shall be stranded.
  - c. Install all wiring (low voltage and line voltage) in conduit, except PV string wiring at modules, which may be run outside of raceway per Exhibit A, Section 2.
  - d. Do not pull conductors into conduit until raceways and boxes have been thoroughly cleaned and swabbed as necessary to remove water and debris.
  - e. Approximately balance all AC circuits about the neutral conductors in AC collector panels.
  - f. All wire and cable shall bear the Underwriters' Label or equivalent NRTL label, brought to the job in unbroken packages.
  - g. The equipment grounding conductor shall be insulated or bare copper; where it is insulated, the insulation shall be colored green.
  - h. Install all circuits in one continuous section unless splices are approved by Owner. Exercise care in pulling to avoid damage or disarrangement of conductors, using approved grips. No cable shall be bent to smaller radius than the spool on which it was delivered from the manufacturer. Color code feeder cables at terminals. Provide identifying linen tags in each pull box
- J. Fire stopping: as manufactured by 3M Fire Protection Products or equal.
  1. Fire-rated and smoke barrier construction: Maintain barrier and structural ceiling fire and smoke resistance ratings including resistance to cold smoke at all penetrations, connections with other surfaces or types of construction, at separations required to permit building movement and sound vibration absorption, and at other construction gaps.
  2. Systems or devices listed in the UL Fire Resistance Directory under categories XHCR and XHEZ may be used, providing that it conforms to the construction type, penetration type, annular space requirements and fire rating involved in each separate instance, and that the system be symmetrical for wall penetrations. Systems or devices must be asbestos free.

### **PART 3 - EXECUTION**

#### **3.01 INSPECTION**

- A. Examine the areas and conditions under which the work of this Section will be installed. Correct conditions detrimental to the proper and timely completion of the Work. Do not proceed until unsatisfactory conditions have been corrected.

#### **3.02 FIELD QUALITY CONTROL**

- A. All workmanship shall be first class and carried out in a manner satisfactory to and approved by the Owner.



- B. This Contractor shall personally, or through an authorized and competent representative, constantly supervise the work and so far as possible keep the same foreman and workmen on the job throughout.

**3.03 INSTALLATION/APPLICATION/ERECTION**

- A. All cutting, repairing and structural reinforcing for the installation of this work shall be done by the General Contractor in conformance with the Owner's requirements.
- B. Excavate and trench or directional bore as necessary for the electrical installation, and when the work has been installed, inspected and approved, backfill all excavations with clean earth from excavation, or imported sandy soil in maximum 8" (eight-inch) layers, moisten and machine tamp to 95% compaction, and restore the ground and/or paving or floor surfaces to their original condition.
- C. Floor Mounted Inverter Installation: Provide mounting channels for grouting into floor or slab. Channels shall be properly drilled to receive the equipment placed flush in floor, leveled and secured in place prior to pouring of floor, of length as required for switchboard. Bolt or weld switchboard to channels.
- D. Furnish and install all disconnect switches as required by code (AC and DC).

**3.04 EARTHQUAKE RESISTANT INSTALLATION & FASTENING:**

- A. All electrical equipment and raceways shall be designed to withstand forces generated by earthquake motions. As a minimum, equipment and equipment frames shall be designed to withstand a force of 25% of the weight of the equipment and frame acting at its center of gravity. Anchorage of the equipment and/or frame to the structure shall be for a force of 50% gravity also acting at the center of gravity.
- B. For floor mounted inverters and switchboards / distribution panels, the above values shall be doubled. Design stresses in either case may be increased 1/3 over normal allowable stresses but never beyond yield.

**3.05 ADJUSTING AND CLEANING**

- A. All electrical equipment, including existing equipment not "finish painted" under other sections, shall be touched up where finished surface is marred or damaged.
- B. All equipment shall be left in clean condition, with all shipping and otherwise unnecessary labels removed there from.

**3.06 IDENTIFICATION**

- A. Inverters, combiner boxes, pull boxes, switchboards, panel boards, distribution circuit breakers, disconnect switches, and related electrical enclosures shall be properly identified by means of engraved laminated plastic descriptive nameplates mounted on apparatus using stainless steel screws or permanent epoxy adhesive where set screws are not feasible. Standard adhesives alone are not acceptable. Nameplates shall have white letters with black background. Cardholders in any form are not acceptable.
- B. Provide all required safety and identification placards as required by code and as designated in Exhibit A, Section 2.

**3.07 PAINTING OF EQUIPMENT**

- A. Factory Applied: Electrical equipment shall have factory-applied painting systems which shall, as a minimum, meet the requirements of NEMA ICS 6 corrosion-resistance test, except equipment specified to meet requirements of ANSI C37.20 shall have a finish as specified in ANSI C37.20.
- B. Field Applied: Paint electrical equipment as required to match finish or meet safety criteria.

**3.08 TESTING**

- A. General:
  - 1. All inspections and tests shall be in accordance with the International Electrical Testing Association - Acceptance Testing Specifications ATS-2009 (referred to herein as NETA ATS-2009).
  - 2. Final test and inspection may be conducted in presence of Owner: Tests shall be conducted at the expense of and by the Contractor at a mutually agreed time. Submit written test reports.
  - 3. The electrical installation shall be inspected and tested to ensure safety to building occupants, operating personnel, conformity to code authorities, and final Construction Shop Drawings.
  - 4. Final Inspection Certificates: Prior to final payment approval, deliver to the Owner, with a copy to the Owner, signed certificates of final inspection by the appropriate inspection authority.
    - a. Grounding System:
      - 1) All ground connections shall be checked and the entire system shall be checked for continuity. The resistance of the ground system at each site shall be measured using a 3 point fall-of-potential method. The maximum ground resistance shall be three ohms.
      - 2) Ground tests shall meet the requirements of the National Electric Code, Article 250.
      - 3) All PV system grounding shall meet the requirements of NEC Article 690.

**END OF SECTION**