



6: District Facilities Assessment

Site Data Evaluation for Florence Elementary School

SITE DATA	FLORENCE ES	107
Site Net Acreage:	3.3	
Total Permanent Building Sq. Footage:	29,917	
Total Quantity of Classrooms:	16	
Quantity of Permanent Classrooms	12	
Number of Permanent Buildings	4	
School Program Capacity	279	
Current Enrollment - 2007-08	281	
Projected Enrollment - 2016-17:	252	
Student to Acre Ratio:	85	
Quantity of Portable Classrooms	4	
% of Total Classrooms in Portables	25%	
Quantity of Portable Buildings on Site	7	
Quantity of Undersized Classrooms	1	
% of Undersized Classrooms	6%	
API Rating (2007 Base Statewide Rank)	8	
Quantity of buildings over 50 years	0	
Age of Building-% over 50 years	0%	
FCA Rating	Poor	
Climate Control	II	
ADA Report	Poor	
Delta from Capacity	-2	

Site Findings:

- The school is deficient 2,009 sq. ft. of administration & instructional support space to meet district standards
- 7 Portables are not certified. 1 portable is over 40 years old
- 1 classroom is used for Science prep
- Site has requested more space for Spanish class

Input From Site Surveys:

- No survey received from school

Input from Cluster Meetings:

- Need better ventilation
- Cracks in floors everywhere reported
- Rats and roaches reported to be a problem
- Request windows
- Request that lunch court be washed down
- Request more parking
- Request wireless in portables
- Request renovation of cafeteria to allow better utilization of space, giving kids more time to eat lunch