



## 6: District Facilities Assessment

### Site Data Evaluation for Logan School

SITE DATA	LOGAN ES	177
Site Net Acreage:	6.4	
Total Permanent Building Sq. Footage:	54,121	
Total Quantity of Classrooms:	48	
Quantity of Permanent Classrooms	25	
Number of Permanent Buildings	1	
School Program Capacity	944	
Current Enrollment - 2007-08	619	
Projected Enrollment - 2016-17:	663	
Student to Acre Ratio:	97	
Quantity of Portable Classrooms	23	
% of Total Classrooms in Portables	48%	
Quantity of Portable Buildings on Site	22	
Quantity of Undersized Classrooms	20	
% of Undersized Classrooms	42%	
API Rating (2007 Base Statewide Rank)	2	
Quantity of buildings over 50 years	0	
Age of Building-% over 50 years	0%	
FCA Rating	Fair	
Climate Control	11 w/ 100% AC	
ADA Report	Fair	
Delta from Capacity	325	

#### Site Findings:

- The school is deficient 7,088 sq. ft. of administration & instructional support space to meet district standards
- 2 portables are not certified. 5 portables are over 40 years old
- Site is unhappy with loft classrooms
- Site enlarged groups of loft classrooms which has reduced classroom count by 3
- Joint-use library that was planned is on hold, waiting for city to commit funds

#### Input from Site Survey:

- New classrooms needed to replace “loft” classrooms
- Poor ventilation reported in portable classrooms. Need upgraded HVAC system
- Plumbing/drainage needs retrofitting/replacement due to frequent maintenance
- New student drop-off area and additional parking needed due to safety concerns and congestion
- Campus beautification/landscaping and artificial playground turf requested
- Fire alarm and bell reported not functioning in portables and need to be repaired/replaced

#### Input From Cluster Meetings:

- No additional input received